

manufacturer test report

testing according to DIN EN 50164-1 (VDE 0185 part 201)

Earthing Pipe Clamp Part No. 408 012

material: zinc die casting



DEHN + SÖHNE



non-binding figure

application: overground

conductor connected	test result
1st conductor : round wire 16mm ² copper	N
2nd conductor : conduit 1/2" hot-galvanized steel	

caption

withstand lightning current class H 100 kA (10/350 μ s)

withstand lightning current class N 50 kA (10/350 μ s)

Detailed data of testing conditions can be requested on demand.